

Water Softener Programming Instructions

Tank Size	Gravel	Cubic Feet	Capacity	Based on 20% Fixed Reserve Capacity	Backwash	Brine	Rinse	Regen Meter	Drain Line Flow Control
8 x 44	10 lb	3/4	24K grain	19000 6lb	10 min	60 min 8 min	6 min	02:00:00 am on if appl	1.7 gpm
9 x 48	12 lb	1	32K grain	24000 9.5lb	10 min	60 min 8 min	6 min	02:00:00 am on if appl	2.2 gpm
10 x 35 Cabinet	12 lb	1	32K grain						2.2 gpm
10 x 44	15 lb	1.25	40K grain	32000 12lb	10 min	60 min 8 min	6 min	02:00:00 am on if appl	2.7 gpm
10 x 54	15 lb	1.5	48K grain	38000 14lb	10 min	60 min 8 min	6 min	02:00:00 am on if appl	2.7 gpm
12 x 48	25 lb	2	64K grain	51000 18 lb	10 min	60 min 8 min	6 min	02:00:00 am on if appl	4.0 gpm
12 x 52	25 lb	2	64K grain	51000 18 lb	10 min	60 min 8 min	6 min	02:00:00 am on if appl	4.0 gpm
13 x 54	30 lb	2-2.5	90K grain	64000 24 lb	10 min	60 min 8 min	8 min	02:00:00 am on if appl	5.3 gpm
14 x 65	40 lb	3	90K grain	72000 30 lb	10 min	60 min 8 min	8 min	02:00:00 am on if appl	6.5 gpm
16 x 53	50 lb	3	90K grain	72000 30 lb	10 min	60 min 8 min	8 min	02:00:00 am on if appl	7.0 gpm
16 x 65	50 lb	4	120K grain	96000 36 lb	10 min	60 min 8 min	8 min	02:00:00 am on if appl	8-9 gpm

Iron Breaker™ Programming Instructions *(Program in softening mode or Iron Breaker mode, NOT filtering mode)*

Tank Size	Gravel	Cubic Feet	Media	1000 Gallons or	Backwash	Rinse	Brine	Regen Meter	DLFC
10 x 54	15 lb	1	Filter Ag/NextSand/Katalox Light	every 2 days	10 min	8 min	50 min OFF	12:00:00 am on if appl	5.3 gpm
12 x 48	25 lb	1.5	Filter Ag/NextSand/Katalox Light	every 2 days	10 min	8 min	50 min OFF	12:00:00 am on if appl	9 gpm
13 x 54	30 lb	2	Filter Ag/NextSand/Katalox Light	every 2 days	10 min	8 min	50 min OFF	12:00:00 am on if appl	13 gpm
10 x 54	15 lb	1	CAT HAC	every 2 days	10 min	8 min	50 min OFF	12:00:00 am on if appl	4 gpm
12 x 48	25 lb	1.5	CAT HAC	every 2 days	10 min	8 min	50 min OFF	12:00:00 am on if appl	6.5 gpm
13 x 54	30 lb	2	CAT HAC	every 2 days	10 min	8 min	50 min OFF	12:00:00 am on if appl	8-9 gpm

